# Shelby Wright Test Labs

515 Rosebank Road, Avondale, Auckland 1026, New Zealand
IANZ Accredited Laboratory No. 1438


# Certificate of Compliance

## AS/NZS 4284:2008

**Certificate Reference:** SWTL - R0101
**Date of Issue:** 13th August 2025

This is to certify that the system detailed below, when tested as a representative sample, has met the performance requirements of the Australian National Construction Code (NCC) F3V1 & H2V1 per AS/NZS 4284:2008 for a design wind load equivalent to an **N4 Corner/Exposed wind zone**.

**Client Details**

- **STONEFACE NZ Ltd, for and on behalf of STONE FAÇADE CO Ltd, &**
- **Certified Stone Plus Limited**

**Tested System**

- **Product:** Grespania Coverlam® Ultra Compact Surface (UCS) panels (5.6mm & 12mm thickness).
- **System:** The Coverlam® panels were mounted on a variety of STONEFACE NZ Ltd cladding fixing systems:
  - SLIMLINE20 – *Tweha Panelmate (chem-elastic)*
  - STRUKTEC – *Tweha Panelmate (chem-elastic)*
  - STONEMEC Plus LOAD BRACE – *Tweha Panelmate (chem-elastic)*
  - STONEMEC Plus - *mechanical (back of panel anchor system)*
  - STONEMEC Plus LOAD BRACE – *mechanical (back of panel anchor system)*

**Authorised Signatory**

**Bernard Farrington, IANZ KTP**
*For and on behalf of Shelby Wright Test Labs*

***Disclaimer:*** *This certificate is a summary based on the findings of Test Report* ***SWTL R0101****. The results relate only to the specific sample tested. This document does not replace the full test report, which should be consulted for complete details of the test procedure, sample construction, and observations. This certificate shall not be reproduced except in full.*